



Online Processing Sheet for CTE-CCA (Grant/Reject)

To be PutUp to Chairman / Member Secretary / Unit Heads by the appropriate level

Nagar Palik Nigam, Indore (23510),
PLOT NO:Kabit khedi.,
Nagar Palik Nigam, Indore, Kabit khedi.,
Kabitkhedi/Indore - 452010
DIST : Indore, TAL : Indore, SIDC : Not In SIDC

On Date : 04/02/2014

Inward : 66100
Date : 09/12/2013
(CTE-Fresh)

Applying For : W Validity : 5 Years Category : RED Scale : LARGE
Air Sector : 0 W.W.C. (Klpd): 0.000 (Ind) 1.500 (Dom)
Haz Sector : 0 W.W.G. (Klpd): 0.000 (Ind) 1.000 (Dom)
Investment Air Water Hazardous Paid Amount :
193.80 Crs x 0 x 0 +0 x 0 3000
Payable Fees : Air : 0, Water : 0, Haz : 0 No of Plants : 1 Incenerator : 0

Online Appln,PDFs,Catg,Scale,Fees Scrutinized by : K.L.CHOUHRY,E.E.[1283]

Inspection Team :

Imp. Dt.	To RO/MS	Imp. Dt.	To Unit Hd	Head Em.	To M.S	Chairman	Decision Dt
05/12/2013	28/12/2013	28/12/2013	10/01/2014				

Online Appln (Queries to Industry & Replies)

Online : 66100-17/10/2013 , After 53 Days

Query On: 30/10/2013	Kindly update profile with appropriate datas & upload required document as discuss in the office.and provide the detail of work completion/commissioning of STP.[25/10/2013-1283]~[30/10/2013-1283]
Reply On: 21/11/2013	We have updated the profile with appropriate data and uploaded the required document, as per notification on dated 07 th October 2009 we are update fee details-Submitted DD Details

Inspection@ RO (109489)

Nagar Nigam Indore is applied for CTE under water act for sewerage Treatment Plant (STP) the capacity of 122.5x 2 *245 MLD, This is an Proposed unit at Kabit Khedi Indore and Sewerage Treatment Plant (STP) of Capacity of 78+12= 90 MLD are already functioning at Khabit Khedi Indore. as per proposal submitted by the Municipal Corporation Indore. they have not converted oxidation pond into Aerated Lagoon of 78 MLD. New STP is under construction on the land (Part) of oxidation pond of Existing 78 MLD. They also not submitted the details of proposed sewerage system of Indore city as well as conveyance system of Sewerage. and before finalized the matter deposition of remaining Water Cess matter is to be short out. Application through online contain profile & as per details submitted, it is Municipal Corporation. It is an important project they may be ask for Presentation at H.O. Bhopal, and also asked for Sewage conveyance system. So the application is decided on the Head Office level. [1283]-24/12/2013~ RO Comments/Reply :team from ho should also inspect the sewerage system and etp / I recommend :May be GRANTED-28/12/2013

R.O Head (Queries to Staff)

R.O Staff (Queries to Industry & Replies by Industry)

Scrutiny Comments by HO Staff

~ This is a case of fresh CTE, hence PP may ask to made TO on next date. [10/01/2014],[1127]

Query@HO:

Query On: 13/01/2014	Your application for CTE is received on Narmada XGN file of MPPCB. As required, you are now requested to present your case on power point presentation. The date of presentation is on 06/02/2014 & the venue is conference hall of Head Office of MPPCB, E-5 Arera Colony Parayavaran Parisar BHOPAL.at 10-30 AM. Please note that your absence may lead to rejection of your consent application. [UNH-1007,13/01/2014]
Reply On:	

Legal Branch Comments

Legal Action :

Legal No: 0

Legal Dt:

Hazd Waste HO-Staff / Head Comments

Unit Head Comments

BIODATA

Name of Project -	N. Pulika Nagar, Indore
Activity	STP
Area	9 hect.
Cost -	193.88 Crores
Total Water Cons.	NA
W/W germ	NA
W. put and used	NA
A. put	NA
Solid Waste Cons.	53 MTD
HW	NIL
RO	Reconded.
	Feed Bulshut

Name of Off.


DT of Diss.

Quany

Name of officer :- VIJAY Kumar Ahirwar SE

Presentation Dt - 04/02/14

- Observation: -
- (i) RO detail ER is required to arrive at conclusion.
 - (ii) It appears that nearly 72% sewage shall be collected & channelised for treatment, it may not serve the purpose as balance 28% needs proper attention/treatment etc. Proper Application & required fee is to be submitted by Proposer / Nagar Nigam.
 - (iii)


04/2/14