


## Format for uploading the CETP monitoring data on SPCBs website

S. No.	Name and Address the CETP	Capacity (MLD)	Design inlet quality	Final effluent quality standard or ZLD condition	Date of Monitoring	Waste water treated in CETP (MLD)	Waste water by passed untreated in the area. If any (MLD)	Observed Inlet Quality	Observed Final effluent quality	Status of online CEQMS	Status of hazardous storage/ Disposal
1	2	3	4	5	6	7	8	9	10	11	12
1.	Govindpura Audhyogic Kshetra Pradushan Niwaran Kendra, Plot no. 28, Sector-H, Industrial Area Govindpura, Bhopal-462023	0.900	BOD – 1820 mg/l	pH- 6.5-9.0	24.04.2017	0.355 ML/Day in April 2017	Nil	pH- 7.31	pH- 8.26	Installed & Under Trial	N.A.
		-	COD – 3200 mg/l	BOD – 30 mg/l	-	-	-	BOD – 420 mg/l	BOD – 32.0 mg/l	-	-
		-	CN- 0.20 mg/l	TSS – 100 mg/l	-	-	-	TSS – 528 mg/l	TSS – 106 mg/l	-	-
		-	-	COD – 250 mg/l	-	-	-	COD – 2964 mg/l	COD – 217.36 mg/l	-	-
		-	-	TDS – 2100 mg/l	-	-	-	TDS – 2598 mg/l	TDS – 996 mg/l	-	-

  
**R.S. BHARTI**  
 Junior Scientist  
 Regional Office, MPPCB, Bhopal