


Format for uploading the CETP monitoring data on SPCBs website

S. No.	Name and Address the CETP	Capacity (MLD)	Design inlet quality	Final effluent quality standard or ZLD condition	Date of Monitoring	Waste water treated in CETP (MLD)	Waste water by passed untreated in the area. If any (MLD)	Observed Inlet Quality	Observed Final effluent quality	Status of online CEQMS	Status of hazardous storage/ Disposal
1	2	3	4	5	6	7	8	9	10	11	12
1.	Govindpura Audhyogic Kshetra Pradushan Niwaran Kendra, Plot no. 28, Sector-H, Industrial Area Govindpura, Bhopal-462023	0.900	BOD - 1820 mg/l	pH- 6.5-9.0	22.03.2017	0.309 ML/Day in March 2017	Nil	pH- 6.75	pH- 8.13	Installed & Under Trial	N.A.
		-	COD - 3200 mg/l	BOD - 30 mg/l	-	-	-	BOD - 520 mg/l	BOD - 36.0 mg/l	-	-
		-	CN- 0.20 mg/l	TSS - 100 mg/l	-	-	-	TSS - 526 mg/l	TSS - 113 mg/l	-	-
		-	-	COD - 250 mg/l	-	-	-	COD - 2800 mg/l	COD - 210 mg/l	-	-
		-	-	TDS - 2100 mg/l	-	-	-	TDS - 2963 mg/l	TDS - 1013 mg/l	-	-


R.S. BHARTI
 Junior Engineer
 Regional Office, MPPCB, Bhopal