


Format for uploading the CETP monitoring data on SPCBs website

S. No.	Name and Address the CETP	Capacity (MLD)	Design inlet quality	Final effluent quality standard or ZLD condition	Date of Monitoring	Waste water treated in CETP (MLD)	Waste water by passed untreated in the area. If any (MLD)	Observed Inlet Quality	Observed Final effluent quality	Status of online CEQMS	Status of hazardous storage/ Disposal
1	2	3	4	5	6	7	8	9	10	11	12
1.	Govindpura Audhyogic Kshetra Pradushan Niwaran Kendra, Plot no. 28, Sector-H, Industrial Area Govindpura, Bhopal-462023	0.900	BOD-1820 mg/l	pH- 6.5-9.0	26.10.2017	0.219 ML/ Day in October 2017	Nil	pH- 6.76	pH- 7.52	Order Placed for Installation	N.A.
			COD-3200 mg/l	BOD-30 mg/l				BOD-510 mg/l	BOD-36 mg/l		
			CN- 0.20 mg/l	TSS-100 mg/l				TSS-458 mg/l	TSS-134 mg/l		
				COD-250 mg/l				COD-2692 mg/l	COD-192 mg/l		
				TDS-2100 mg/l				TDS-2388 mg/l	TDS-1026 mg/l		


R.S. BHARTI
 Junior Scientist
 Regional Office, MPPCB, Bhopal