

Format for uploading the CETP monitoring data on SPCBs website

S. No.	Name and Address the CETP	Capacity (MLD)	Design inlet quality	Final effluent quality standard or ZLD condition	Date of Monitoring	Waste water treated in CETP (MLD)	Waste water by passed untreated in the area. If any (MLD)	Observed Inlet Quality	Observed Final effluent quality	Status of online CEQMS	Status of hazardous storage/ Disposal
1	2	3	4	5	6	7	8	9	10	11	12
1.	Govindpura Audhyogic Kshetra Pradushan Niwaran Kendra, Plot no. 28, Sector-H, Industrial Area Govindpura, Bhopal-462023	0.900	BOD - 1820 mg/l	pH- 6.5-9.0	05.05.2017	0.350 ML/ Day in May 2017	Nil	pH- 6.89	pH- 8.32	Installed & Under Trial	N.A.
		-	COD - 3200 mg/l	BOD - 30 mg/l	-	-	-	BOD - 160 mg/l	BOD - 36.0 mg/l	-	-
		-	CN- 0.20 mg/l	TSS - 100 mg/l	-	-	-	TSS - 394 mg/l	TSS - 122 mg/l	-	-
		-	-	COD - 250 mg/l	-	-	-	COD - 889.2 mg/l	COD - 237.12 mg/l	-	-
		-	-	TDS - 2100 mg/l	-	-	-	TDS - 2924 mg/l	TDS - 1140 mg/l	-	-


R.S. BHARTI
 Junior Scientist
 Regional Office, MPPCB, Bhopal