

BRIEF BIO-DATA OF THE INDUSTRY

(Review of pollution control arrangement regarding Consent to Operate for 1 x 660 MW TPP [Unit-1])

S.	Description	Remark
1	Name of the industry and location	M/s. Sasan Power Ltd. Village: Sidhikhurd, Teh. & Dist. Singrauli
2	Name of product	Coal based Thermal- 6 x 660 = 1980 MW (Total) Power Plant 3 x 660 = 1980 MW (CTO granted) 1 x 660 = 660 MW (Unit-I) <ul style="list-style-type: none"> ▪ Out of total 6 x 660 = 1980 MW, Consent to Operate has been issued for 3 x 660 = 1980 MW earlier. ▪ Now industry has applied for 1 x 660 (Unit-1) which is ready for commercial production.
3	Status of Environmental Clearance	Environmental Clearance issued by MoEF on dt. 23/11/06 & 21/07/09
4	Status of Permission to Establish	<ul style="list-style-type: none"> ▪ Permission to Establish issued on dated: 13/02/09 and amended letter dated: 22/04/09, 23/11/10, 06/01/12.
5	Point for discussion	<ul style="list-style-type: none"> ✓ Industry has presented the same case previously on dated: 25/04/14. As per the feedback during presentation, the main issue was that the industry shall complete the work of AWRS before granting consent to operate for Unit-I. ✓ As per reply submitted by industry vide letter dated: 08/05/14, stated that the overall commissioning of the AWRS will be upto 15th July, 2014. ✓ Industry has requested vide their letter dated: 21/05/14 to review the progress of the work done and for issuance of consent to operate (Unit-1) as soon as possible. ✓ In this regard R.O. Singrauli has submitted a inspection report on dated: 21/05/14 stating that the consent to operate for Unit-1 may be granted with the condition that industry shall complete and commission AWRS upto 30/06/14. Other observation of the IR are as follows: <ul style="list-style-type: none"> ◆ Intake Well (Decantation well) has been completed. ◆ Overflow collection lagoon with lining has been completed. ◆ Laying of pipeline from overflow lagoon to pump house i.e. 900 mt. is under progress. For pipeline pedestal has been completed. ◆ For installation of 03 nos. pumps the super structure is not constructed. ◆ Pipeline work is completed upto 800 mt. (out of 1500 mt.) from pump house to clarifier in plant. ◆ The construction of clarifier with mechanical equipment has been completed. ◆ The capacity details of ash dyke is also enclosed with IR.
6	R.O. recommendation	R.O. recommended for Consent to Operate for 1 x 660 MW Unit-1 with a condition that industry shall complete the work of AWRS upto 30/06/14.

Feed Back Sheet

M/s. Sasan Power Ltd. (Unit-1)
Village: Sidhikhurd, Teh. & Dist. Singrauli

(Review of pollution control arrangement regarding Consent to Operate
for 1 x 660 MW TPP [Unit-1])

1	Name of Officer/ Designation	V K Ahirwar SE
2	Date of Discussion	22/5/14
3	Query raised/Suggestions/ Recommendations	<p>① It should be ensured that AURS system should start function by 30th June 2014.</p> <p>② Hence all civil, Mechanical installations work must be over by this time An affidavit may be obtained for this.</p>

(Signature)


22/5/14

Feed Back Sheet

**M/s. Sasan Power Ltd. (Unit-1)
Village: Sidhikhurd, Teh. & Dist. Singrauli**

**(Review of pollution control arrangement regarding Consent to Operate
for 1 x 660 MW TPP [Unit-1])**

1	Name of Officer/ Designation	Abhay Saraf EE.
2	Date of Discussion	22-05-2014
3	Query raised/Suggestions/ Recommendations	<p>As recommended by R.O. Case may be considered for CTO with condition that industry shall submit weekly progress report with photographs and complete all the works before or on 30-06-2014.</p> <p>- Industry shall also submit undertaking in this regard.</p>


(Signature) 

Feed Back Sheet

**M/s. Sasan Power Ltd. (Unit-1)
Village: Sidhikhurd, Teh. & Dist. Singrauli**

**(Review of pollution control arrangement regarding Consent to Operate
for 1 x 660 MW TPP [Unit-1])**

1	Name of Officer/ Designation	H.S. Mahiya EE
2	Date of Discussion	22.5.14
3	Query raised/Suggestions/ Recommendations	may be considered as recommended by RO and simultaneously a firm commitment may be obtained for completion of work in committed period i.e. 30/6/14 and ensure compliance of all the conditions; stipulated in consent.


(Signature)

Feed Back Sheet

**M/s. Sasan Power Ltd. (Unit-1)
Village: Sidhikhurd, Teh. & Dist. Singrauli**

**(Review of pollution control arrangement regarding Consent to Operate
for 1 x 660 MW TPP [Unit-1])**

1	Name of Officer/ Designation	M. K. Mandreai EE
2	Date of Discussion	22/5/14
3	Query raised/Suggestions/ Recommendations	<p>- Ind. shall submit undertaking for completion of work up to 30/6/14</p> <p>- case may be considered as per recommendation of RO E/R dt. 21/5/14.</p>

(Signature)

Feed Back Sheet

M/s. Sasan Power Ltd. (Unit-1)
Village: Sidhikhurd, Teh. & Dist. Singrauli

(Review of pollution control arrangement regarding Consent to Operate
for 1 x 660 MW TPP [Unit-1])

1	Name of Officer/ Designation	Ganwant Joshi , Chief chemist.
2	Date of Discussion	22/5/2014
3	Query raised/Suggestions/ Recommendations	<p>Looking to the speed of progress the proposal may be considered. RO needs to regularly check the progress of the project of slurry transport & Ash dyke construction.</p> <p>Return pipe line and other work may completed by 30th June. An undertaking to this effect must be given by project proponents.</p>


(Signature)